

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3774-0006:111

Page 1 of 1

CATEGORY: Electric Locks

LISTEE: Sargent Manufacturing, 100 Sargent Drive, New Haven, CT 06536
Contact: *Dan Picard (203) 498-5634 Fax (203) 498-5600

DESIGN: Models 7800 and 8200 series mortise type with 3/4" latch bolt, electrically controlled single point locks. Unit is designed to control the operation on either the knobsets or level handles of a mortise lockset on one or both sides of a fire door. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 24 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number and UL label.

APPROVAL: Listed as electric door locks suitable for single or double outward swinging fire doors fire rated up to 3 hours. These units are intended for use on doors with a maximum opening of 4' x 10' for single and 8' x 10' for double. Authority having jurisdiction shall be consulted prior to installation.

*Rev. 06-08-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued:

JUNE 6, 2003

*Listing Expires **June 30, 2004***

Authorized By:

DIANE K. AREND, Senior Deputy
Program Manager